

NOTES:

- Saw cut pipe at station A and B unless pipe bell corresponds with location.
- 2. Offset pipe joints will not be permitted.
- 3. Where existing pipe is at least 10" or larger, a sewer saddle may be used as shown in standard detail BC 830.17.
- 4. Contractor shall maintain all flows in accordance with all state and local requirements.

A 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5	APPROVED:
A PARTIE AND A PAR	Byan Son &
1797	Mules Columnia
1137	DIRECTOR, DEPARTMENT OF PUBLIC WORKS

CITY OF BALTIMORE
DEPARTMENT OF PUBLIC WORKS
BUREAU OF WATER AND WASTEWATER

ISSUED

3 / 2008

REVISED REVISED

PIPE REPLACEMENT DETAIL FOR NEW HOUSE CONNECTIONS TO EXISTING SEWERS STANDARD NO. BC 830.18

SCALE: NONE SHEET 1 OF 1