




NOTES:

1. STONE (NO. 6 AGGREGATE) MAY BE SUBSTITUTED FOR GRAVEL.
2. WHEN 2 TIER TRENCH SUPPORT IS REQUIRED, ADD 24" TO "W" FOR CALCULATING THE AMOUNT OF PAVING NEEDED FOR TRENCH REPAIR.

REINFORCED CONCRETE PIPE					
DIMENSIONS					
D	OD	ODB	A	B	W
15"	19"	23"	7"	6"	43"
18"	22.5"	27"	7"	6"	47"
21"	25.75"	30.5"	7"	6"	50.5"
24"	29"	34"	7"	6"	54"
27"	32.25"	37.5"	7"	6"	57.5"
30"	36"	41.5"	7"	6"	61.5"
33"	39.5"	45.5"	7"	6"	65.5"
36"	42.75"	49"	8"	6"	69"
42"	50"	57.5"	8"	6"	77.5"
48"	57"	66"	9"	6"	86"
54"	64"	72.5"	9"	7"	92.5"
60"	72"	75.5"	6"	8"	95.5"
66"	79"	81"	6"	8"	101"
72"	86"	88"	6"	9"	108"

	APPROVED :  HEAD, BUREAU OF WATER AND WASTEWATER	CITY OF BALTIMORE DEPARTMENT OF PUBLIC WORKS BUREAU OF WATER AND WASTEWATER	ISSUED	REVISED	REVISED	
	 DIRECTOR, DEPARTMENT OF PUBLIC WORKS		3 / 2008			
	GRAVEL CRADLE FOR RCP STORM DRAINS		STANDARD NO. BC 302.02			SCALE : NONE