




**NOTES:**

1. SPECIFICATIONS: LATEST DPW
2. CONCRETE: SHALL BE MIX 3
3. REINFORCING: DEFORMED STEEL BARS
4. CHAMFER: ALL EXPOSED EDGES 1"x1" OR AS DIRECTED
5. COVER: MINIMUM COVER TO BE 2" UNLESS OTHERWISE NOTED

	APPROVED: 	<b>CITY OF BALTIMORE</b> <b>DEPARTMENT OF PUBLIC WORKS</b> <b>BUREAU OF WATER AND WASTEWATER</b>	ISSUED 3 / 2008	REVISED 	REVISED 
	HEAD, BUREAU OF WATER AND WASTEWATER 	DIRECTOR, DEPARTMENT OF PUBLIC WORKS	<b>TYPE 'F' ENDWALL CIRCULAR AND ELLIPTICAL PIPE</b>	<b>STANDARD NO.</b> <b>BC 358.02</b>	
			SCALE : NONE	SHEET 1 OF 2	