

- 1. TO BE USED WHERE SIDEWALK IS SEPARATED FROM ADJACENT CURB. THIS STANDARD MAY BE MODIFIED TO SUIT A PARTICULAR LOCATION.
- 2. WHERE 48" SIDEWALK CAN NOT BE PROVIDED, A DESIGN WAIVER MUST BE REQUESTED.
- 3. NO TRAVERSABLE SLOPE ON THE RAMP OR SIDEWALK SHALL EXCEED 12:1 IN THE DIRECTION OF PEDESTRIAN TRAVEL, OR 50:1 PERPENDICULAR TO THE DIRECTION OF PEDESTRIAN TRAVEL.
- 4. EXPANSION JOINT MATERIAL SHALL BE INSTALLED IN ACCORDANCE WITH STD. BC 655.01.
- 5. SIDEWALK RAMP SHALL BE INCLUDED IN PRICE BID FOR CONCRETE SIDEWALK. DEPRESSED CURB AND CURB TRANSITION FOR SIDEWALK RAMP SHALL BE INCLUDED IN PRICE BID FOR CURB OR CURB & GUTTER. DETECTABLE WARNING SURFACE SHALL BE PAID FOR ON A SQUARE FOOT BASIS.
- 6. SIDEWALK RAMPS TO BE SHOWN ON PLANS SYMBOLICALLY AND REFERENCED WITH THE CENTER OF THE RAMP ALIGNED TO A STATION ON THE CONSTRUCTION CENTERLINE. SEPARATE DETAILS SHALL BE SHOWN WHERE PROPOSED RAMP VARIES FROM STANDARD CASES.

