



#### NOTES

1. 3-3" DUCTS TO BE INCLUDED IN THE DUCT SECTION WHERE INDICATED ON PLANS.
2. ALL CONCRETE SHALL BE MIX NO. 1.
3. THIS DIMENSION SHALL APPLY WHEN CONDUITS ARE INSTALLED IN PARALLEL SYSTEMS.
4. TYPICAL SPACERS SHALL BE PLACED AT EACH JOINT AND EVERY FIVE (5) FEET THEREAFTER.
5. ALL DIMENSIONS ARE BASED ON 1/4" WALL THICKNESS

#### FOR 5" DUCT

CAT. CODE	TYPE	A	B	H	W
82430	X	1'-7"	1'-1 1/2"	1	2
82417	O	1'-7"	1'-9"	2	2
82415	M	1'-7"	2'-4 1/2"	3	2
82413	K	1'-7"	3'-0"	4	2
82410	H	1'-5"	3'-7 1/2"	5	2
82416	N	2'-6"	1'-9"	2	3
82414	L	2'-10"	1'-9"	2	4
82411	I	3'-5 1/2"	1'-9"	2	5
82433	Y	0'-11 1/2"	1'-1 1/2"	1	1

#### FOR 3" DUCT

CAT. CODE	TYPE	A	B	H	W
82435	Y	0'-9 1/2"	0'-11 1/2"	1	1
82432	X	1'-3"	0'-11 1/2"	1	2
82422	P	1'-8 1/2"	0'-11 1/2"	1	3



APPROVED:

*Khalel J. Zane*  
 CHIEF, CONDUIT DIVISION  
*Khalel J. Zane*  
 DIRECTOR, DEPARTMENT OF TRANSPORTATION

CITY OF BALTIMORE  
 DEPARTMENT OF TRANSPORTATION  
 CONDUIT DIVISION

#### STANDARD DUCT SECTIONS

ISSUED	REVISED	REVISED
8 / 2010		
STANDARD NO. BC 824.01-1		
SCALE : NONE	SHEET 1 OF 2	