




Note:

House connections to be laid not less than 15" below cellar floor if depth of sewer will allow except where "Written Request" is made for connection above floor; connections must be placed at greater depth wherever necessary to properly drain fixtures in cellar.

	APPROVED :  HEAD, BUREAU OF WATER AND WASTEWATER	CITY OF BALTIMORE DEPARTMENT OF PUBLIC WORKS BUREAU OF WATER AND WASTEWATER	ISSUED	REVISED	REVISED	
	 DIRECTOR, DEPARTMENT OF PUBLIC WORKS		3 / 2008			
	TYPICAL INSTALLATIONS OF STANDPIPE HOUSE CONNECTIONS		STANDARD NO. BC 830.16			SCALE : NONE