



1" SINGLE METER SETTING
 THE ENTIRE METER SETTING
 MUST BE FACTORY SETTING
 ASSEMBLED, USE FORD NO.
 SDYS6466B-3 WITH A34
 (3/4"x1" METER) ADAPTERS,
 MUELLER B5041 OR
 APPROVED EQUAL.

NOTE:
 SEE STD. NO. BC 853.01 FOR METER VAULT.

**ONLY FOR USE IN
 BALTIMORE COUNTY**



APPROVED:

[Signature]

HEAD, BUREAU OF WATER AND WASTEWATER

[Signature]

DIRECTOR, DEPARTMENT OF PUBLIC WORKS

CITY OF BALTIMORE
 DEPARTMENT OF PUBLIC WORKS
 BUREAU OF WATER AND WASTEWATER

STANDARD INSTALLATION
 FOR FIRE PROTECTION
 1 1/2" WATER SUPPLY SERVICE
 (3/4" METER) FOR 6" MAIN AND LARGER

| | | |
|-----------------------------------|--------------|---------|
| ISSUED | REVISED | REVISED |
| 3 / 2008 | | |
| STANDARD NO. BC 841.05 | | |
| SCALE: NONE | SHEET 1 OF 1 | |