



SIZE	4"	6"
A	8'-4"	9'-10"
B	4'-6"	5'-6"
C	9"	9"
D	2'-3"	2'-9"
E	13 1/2"	14 1/2"
F	11"	14 1/2"
G	2'-8"	2'-8"
H	3'-0"	3'-6"
L	4'-11"	5'-8"
N	6"	6"
P	24"	24"
R	4'-3" 4'-9"	3'-10" 4'-4"
S	1'-5"	1'-10"
①	#4@12	#4@12
②	#5@6	#5@6
ML	29"	36 1/2"
BP	4"	6"

NOTES:

1. FOR CURB SETBACK, SEE STD. NO. BC 851.01.
2. CONCRETE SHALL BE MIX 3.



APPROVED:
[Signature]
 HEAD, BUREAU OF WATER AND WASTEWATER
[Signature]
 DIRECTOR, DEPARTMENT OF PUBLIC WORKS

CITY OF BALTIMORE
 DEPARTMENT OF PUBLIC WORKS
 BUREAU OF WATER AND WASTEWATER

STANDARD INSTALLATION
 OF 4" & 6"
 WATER SUPPLY SERVICES
 (4" & 6" METERS)

ISSUED	REVISED	REVISED
3 / 2008		

STANDARD NO.
 BC 842.01

SCALE: NONE SHEET 1 OF 1