


ROOF SLAB MATERIAL										CONCRETE QUANTITY (CUBIC YARDS)		
SIZE	T	REBARS	STRAIGHT BARS							WALLS	FLOOR	ROOF SLAB
			①	②	③	④	⑤	⑥	⑦			
4"	10"	#6@6"	18@5'-8"	3@1'-8"	10@9'-6"	3@3'-7"	4@3'-3"	3@3'-7"	3@1'-8"	5.18	1.09	1.80
6"	10"	#6@6"	20@6'-8"	3@2'-2"	12@11'-0"	3@4'-4"	4@3'-3"	3@4'-4"	3@2'-2"	6.08	1.47	2.45



APPROVED:

 HEAD, BUREAU OF WATER AND WASTEWATER

 DIRECTOR, DEPARTMENT OF PUBLIC WORKS

CITY OF BALTIMORE
 DEPARTMENT OF PUBLIC WORKS
 BUREAU OF WATER AND WASTEWATER

STANDARD VAULT
 FOR 4" & 6"
 WATER SUPPLY SERVICES

ISSUED	REVISED	REVISED
3 / 2008		
STANDARD NO. BC 842.03		
SCALE : NONE	SHEET 1 OF 1	