



NOTES:

1. CONCRETE SHALL BE MIX 3.
2. FOR 12" F.M. USE 10" F.M. VAULT WITH CORRESPONDING DOMESTIC METERS.

SIZE	4" F.M. WITH 2", 1 1/2", 1 3/4", OR 5/8" DOM. METER	6" F.M. WITH 2", 1 1/2", 1 3/4", OR 5/8" DOM. METER	8" F.M. WITH 2", 1 1/2", 1 3/4", OR 5/8" DOM. METER	10" F.M. WITH 2", 1 1/2", 1 3/4", OR 5/8" DOM. METER
A	4'-3"	5'-3"	5'-11"	7'-2"
B	5'-7 1/2"	6'-6"	7'-6"	9'-0"
C	9"	9"	9"	9"
D	2'-9 3/4"	3'-3"	3'-9"	4'-6"
E	9"	9"	9"	9"
F	1'-4"	1'-5"	1'-6"	1'-8"
G	2'-8"	2'-5"	2'-2"	2'-4"
H	3'-6 3/4"	4'-0"	4'-6"	5'-3"
K	3'-6 3/4"	4'-0"	4'-6"	5'-3"
L	2'-7"	3'-1"	3'-6"	3'-10"
M	3'-2"	3'-8"	3'-11"	4'-10"
N	6"	6"	6"	6"
P	18"	24"	30"	30"
R	4'-3" TO 4'-9"	4'-4" TO 4'-10"	4'-3" TO 4'-9"	3'-6" TO 4'-0"
S	1'-2 1/2"	1'-5 1/2"	1'-9 1/2"	2'-6"



APPROVED: *[Signature]*
 HEAD, BUREAU OF WATER AND WASTEWATER
[Signature]
 DIRECTOR, DEPARTMENT OF PUBLIC WORKS

CITY OF BALTIMORE
 DEPARTMENT OF PUBLIC WORKS
 BUREAU OF WATER AND WASTEWATER
 STANDARD VAULT FOR
 4", 6", 8", 10", & 12" F.M. METERS
 WITH SMALL DOMESTIC METERS

ISSUED	REVISED	REVISED
3 / 2008		
STANDARD NO. BC 846.01		
SCALE: NONE	SHEET 1 OF 2	