




	4" F.M. WITH BYPASS	6" F.M. WITH BYPASS	8" F.M. WITH BYPASS	10" F.M. WITH BYPASS	12" F.M. WITH BYPASS
SIZE	4"	6"	8"	10"	12"
A	7'-11"	9'-8"	10'-10"	13'-0"	13'-6"
B	5'-6"	6'-0"	6'-11"	8'-6"	8'-6"
C	9"	9"	9"	9"	9"
D	2'-9"	3'-0"	3'-5 1/2"	4'-3"	4'-3"
E	9"	9"	9"	9"	9"
F	1'-3"	1'-2"	1'-4"	1'-8"	1'-7"
G	2'-8"	2'-5"	2'-2"	2'-2"	2'-2"
H	3'-6"	3'-9"	4'-2 1/2"	5'-0"	5'-0"
L	4'-8 1/2"	5'-7"	6'-2"	7'-3"	7'-6"
N	6"	6"	6"	6"	6"
P	30"	30"	30"	30"	30"
R	4'-5" 4'-11"	4'-5" 4'-11"	4'-4" 4'-10"	3'-8" 4'-2"	3'-8" 4'-2"
S	1'-2 1/2"	1'-5 1/2"	1'-9 1/2"	2'-6"	2'-6"
①	#4@12"E.W.	#4@12"E.W.	#4@12"E.W.	#4@9"E.W.	#4@9"E.W.
②	#5@6"	#5@6"	#5@6"	#5@4 1/2"	#5@4 1/2"

	APPROVED :	<p align="center">CITY OF BALTIMORE DEPARTMENT OF PUBLIC WORKS BUREAU OF WATER AND WASTEWATER</p> <p align="center">REBAR SCHEDULE FOR STANDARD VAULT FOR 4", 6", 8", 10", &amp; 12" F.M. METERS</p>	ISSUED	REVISED	REVISED
	 HEAD, BUREAU OF WATER AND WASTEWATER		3 / 2008		
	 DIRECTOR, DEPARTMENT OF PUBLIC WORKS		<b>STANDARD NO. BC 847.01</b>		
			SCALE : NONE	SHEET 2 OF 3	