


D.C. METER	WATER SUPPLY SERVICE		A	B	C
	SIDE CONN.	WITH TEE			
4"	3/4" - 1"	1 1/2", 2"	4'-9"	3'-9"	AS PER STD. NOS. BC 836 TO 840.
6"	3/4"-1 1/2"	2"	5'-4"	4'	
8"	3/4"-2"	N/A	5'-10"	4'	
10"	3/4"-2"	N/A	6'	4'	

OPENING AROUND PIPE TO BE BRICKED UP ON THE OUTSIDE OF VAULT AFTER METER IS INSTALLED.



APPROVED:  
*[Signature]*  
 HEAD, BUREAU OF WATER AND WASTEWATER  
*[Signature]*  
 DIRECTOR, DEPARTMENT OF PUBLIC WORKS

CITY OF BALTIMORE  
 DEPARTMENT OF PUBLIC WORKS  
 BUREAU OF WATER AND WASTEWATER

STANDARD INSTALLATION OF  
 4", 6", 8", 10", & 12" FIRE SUPPLY SERVICES  
 WITH WATER SUPPLY SERVICE  
 (NO OUTSIDE FIRE HYDRANTS) WITH  
 TEE AND VALVE (SECTIONAL VAULT)

ISSUED	REVISED	REVISED
3 / 2008		

STANDARD NO.  
 BC 851.01

SCALE: NONE

SHEET 1 OF 1