




NOTES:

1. ON 4" AND 6" PIPE (ALL TYPES) USE 1" CORPORATION STOP, 1" GATE VALVE AND 1" PIPE.
2. ON 4" DUCTILE IRON PIPE USE SERVICE SADDLE (FORD FC202 OR SMITH-BLAIR 315).
3. FOR CONNECTION TO 6" - 12" DUCTILE IRON PIPE, CONTRACTOR MAY INSTALL CORPORATION USING SERVICE SADDLE (MUELLER BR-2B, FORD 202B AY MCDONALD 3826, OR APPROVED EQUAL).
4. ON 4" - 12" HDPE PIPE, USE APPROVED ELECTROFUSION TAPPING SADDLE.
5. BRASS PIPE SHALL BE SEAMLESS RED BRASS PIPE, EXTRA STRONG, CONFORMING TO A.S.T.M. B43 - LATEST EDITION.
6. USE HYDRANT FOR PIPES LARGER THAN 12 INCHES IN DIAMETER. CONNECT HYDRANT WITHIN 5 FEET OF END CAP.

	APPROVED :  HEAD, BUREAU OF WATER AND WASTEWATER	CITY OF BALTIMORE DEPARTMENT OF PUBLIC WORKS BUREAU OF WATER AND WASTEWATER	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 33%;">ISSUED</td> <td style="width: 33%;">REVISED</td> <td style="width: 33%;">REVISED</td> </tr> <tr> <td style="text-align: center;">3 / 2008</td> <td></td> <td></td> </tr> </table>	ISSUED	REVISED	REVISED	3 / 2008		
	ISSUED	REVISED	REVISED						
	3 / 2008								
 DIRECTOR, DEPARTMENT OF PUBLIC WORKS	STANDARD INSTALLATION FOR BLOW	STANDARD NO. BC 857.01							
SCALE : NONE		SHEET 1 OF 1							