


NOTE:
MAKE HOLES IN ANGLE 1/8" LARGER THAN DIAMETER OF BOLT.

SIZE OF MAIN	SIZE OF ANGLE	C TO C EYE BOLT HOLES "C"	DIA. OF EYEBOLT "D"	LENGTH OF EYEBOLT "A"	NO. U.S. THREADS PER INCH	EDGE DIST. "B"
4"	3"x3"x3/8"	11"	3/4"	12"	10	2"
6"	3"x3"x3/8"	12 1/2"	3/4"	12"	10	2"
8"	3"x3"x3/8"	15"	7/8"	12 1/2"	9	2"
10"	4"x3"x3/8"	17 1/2"	1 1/8"	13 1/2"	7	2"
12"	5"x4"x3/8"	20 3/16"	1 1/2"	14 1/2"	6	2 1/4"
16"	6"x4"x1/2"	25 1/4"	1 5/8"	16 3/4"	5 1/2	2 1/2"
20"	6"x4"x3/4"	30 7/8"	2 1/4"	16 3/4"	4 1/2	3 5/8"



APPROVED:
[Signature]
HEAD, BUREAU OF WATER AND WASTEWATER
[Signature]
DIRECTOR, DEPARTMENT OF PUBLIC WORKS

CITY OF BALTIMORE
DEPARTMENT OF PUBLIC WORKS
BUREAU OF WATER AND WASTEWATER

STANDARD
PLUG CLAMPS - 1

ISSUED	REVISED	REVISED
3 / 2008		
STANDARD NO. BC 858.01		
SCALE : NONE		SHEET 1 OF 2